

Aquatic Propagation Facility at Historic Yates Mill County Park
Raleigh, North Carolina
May 11, 2021

ADDENDUM NO. 6
Page 1

HUFFMAN ARCHITECTS, PA
632 PERSHING ROAD
RALEIGH, NORTH CAROLINA 27608
PHONE (919) 270-6455

TO: ALL PRIME BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the original Project Manual and Construction Documents dated March 26, 2021. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. This addendum consists of one (1) page and zero (0) attachments. All documents are distributed digitally.

SPECIFICATIONS

Item No. Description

1. Specification 017823 – “Operations and Maintenance Data” – Make the following revisions”

Part 1, Section 1.4 Closeout Submittals, insert the following new Paragraph C and move existing Paragraph C under this paragraph.

C. Submittal Schedule: Comply with the following schedule for submittal of operating and maintenance manuals.

1. Before Substantial Completion, at 80% billing, when each installation that requires submittal of operating and maintenance manuals is nominally complete, submit three copies of each manual to the Architect. Include a complete index or table of contents of each manual.
2. Final Manual Submittal: Submit each manual in final form prior to requesting inspection for Substantial Completion and at least 15 days before commencing demonstration and training. Architect will return copy with comments.
 - a. Correct or revise each manual to comply with Architect's comments. Submit copies of each corrected manual within 15 days of receipt of Architect's comments and prior to commencing demonstration and training.

2. Specification 09 6723 – “Resinous Epoxy Flooring” – Make the following revisions:

Part 2, Section 2.1 Manufacturers, Paragraph A – Add additional acceptable manufacturers:

5. Neogard

Part 2, Section 2.2 Industrial Resinous Flooring – Add the flowing after Section H:

- I. Slip Resistance: Finished floor must meet a minimum of .42 wet per the DCOF AcuTest.

3. Specification 26 3213 – “Diesel Emergency Engine Generators” – Part 2, Section 2.1 – Add additional acceptable manufacturer:

F. MTU.

END OF ADDENDUM NUMBER SIX

